

NB Electricity Market 18-month Load Forecast, by week

Week Beg. Sundays	Load Forecast(MW)
01-Apr-07	2388
08-Apr-07	2307
15-Apr-07	2225
22-Apr-07	2143
29-Apr-07	2061
06-May-07	1979
13-May-07	1925
20-May-07	1872
27-May-07	1818
03-Jun-07	1764
10-Jun-07	1761
17-Jun-07	1759
24-Jun-07	1756
01-Jul-07	1753
08-Jul-07	1744
15-Jul-07	1735
22-Jul-07	1726
29-Jul-07	1717
05-Aug-07	1708
12-Aug-07	1686
19-Aug-07	1683
26-Aug-07	1694
02-Sep-07	1736
09-Sep-07	1779
16-Sep-07	1822
23-Sep-07	1865
30-Sep-07	1866
07-Oct-07	1955
14-Oct-07	2043
21-Oct-07	2133
28-Oct-07	2222
04-Nov-07	2282
11-Nov-07	2342
18-Nov-07	2402
25-Nov-07	2521
02-Dec-07	2589
09-Dec-07	2658
16-Dec-07	2726
23-Dec-07	2793
30-Dec-07	2862
06-Jan-08	2930
13-Jan-08	2998
20-Jan-08	3067
27-Jan-08	3067
03-Feb-08	3123

NB Electricity Market 18-month Load Forecast, by week

Week Beg. Sundays	Load Forecast(MW)
10-Feb-08	3178
17-Feb-08	3237
24-Feb-08	3044
02-Mar-08	2848
09-Mar-08	2763
16-Mar-08	2676
23-Mar-08	2591
30-Mar-08	2505
06-Apr-08	2419
13-Apr-08	2317
20-Apr-08	2216
27-Apr-08	2113
04-May-08	2012
11-May-08	1956
18-May-08	1902
25-May-08	1848
01-Jun-08	1793
08-Jun-08	1792
15-Jun-08	1792
22-Jun-08	1791
29-Jun-08	1791
06-Jul-08	1790
13-Jul-08	1778
20-Jul-08	1766
27-Jul-08	1754
03-Aug-08	1742
10-Aug-08	1722
17-Aug-08	1707
24-Aug-08	1709
31-Aug-08	1736
07-Sep-08	1779
14-Sep-08	1822
21-Sep-08	1865

The following includes the details of the ambient conditions on which the forecast is based.

The load forecast is based on an End-use Model (sum of forecasted loads by use e.g. water heating, space heating, lighting etc.) for residential loads and an Econometric Model for general service and industrial loads, correlating forecasted economic growth and historical loads. Each of these models is weather adjusted using a 30-year historical average.