

NB Electricity Market 18-month Load Forecast, by week

Week Beg. Sundays	Load Forecast(MW)
04-Nov-07	2217
11-Nov-07	2277
18-Nov-07	2336
25-Nov-07	2456
02-Dec-07	2525
09-Dec-07	2593
16-Dec-07	2660
23-Dec-07	2728
30-Dec-07	2796
06-Jan-08	2865
13-Jan-08	2934
20-Jan-08	3001
27-Jan-08	3067
03-Feb-08	3151
10-Feb-08	3172
17-Feb-08	3043
24-Feb-08	2912
02-Mar-08	2782
09-Mar-08	2697
16-Mar-08	2612
23-Mar-08	2526
30-Mar-08	2440
06-Apr-08	2354
13-Apr-08	2252
20-Apr-08	2150
27-Apr-08	2049
04-May-08	1946
11-May-08	1892
18-May-08	1837
25-May-08	1783
01-Jun-08	1728
08-Jun-08	1727
15-Jun-08	1726
22-Jun-08	1726
29-Jun-08	1726
06-Jul-08	1725
13-Jul-08	1713
20-Jul-08	1701
27-Jul-08	1689
03-Aug-08	1677
10-Aug-08	1647
17-Aug-08	1707
24-Aug-08	1708
31-Aug-08	1743
07-Sep-08	1791

NB Electricity Market 18-month Load Forecast, by week

Week Beg. Sundays	Load Forecast(MW)
14-Sep-08	1839
21-Sep-08	1888
28-Sep-08	1888
05-Oct-08	1961
12-Oct-08	2032
19-Oct-08	2105
26-Oct-08	2249
02-Nov-08	2323
09-Nov-08	2397
16-Nov-08	2471
23-Nov-08	2545
30-Nov-08	2545
07-Dec-08	2666
14-Dec-08	2905
21-Dec-08	2882
28-Dec-08	2906
04-Jan-09	2958
11-Jan-09	3010
18-Jan-09	3062
25-Jan-09	3114
01-Feb-09	3198
08-Feb-09	3281
15-Feb-09	3159
22-Feb-09	3037
01-Mar-09	2912
08-Mar-09	2817
15-Mar-09	2719
22-Mar-09	2623
29-Mar-09	2527
05-Apr-09	2431
12-Apr-09	2337
19-Apr-09	2242
26-Apr-09	2148
03-May-09	2050

The following includes the details of the ambient conditions on which the forecast is based.

The load forecast is based on an End-use Model (sum of forecasted loads by use e.g. water heating, space heating, lighting etc.) for residential loads and an Econometric Model for general service and industrial loads, correlating forecasted economic growth and historical loads. Each of these models is weather adjusted using a 30-year historical average.