

NB Electricity Market 18-month Load Forecast, by week

| Week Beg. Sundays | Load Forecast(MW) |
|----------------------|----------------------|
| 29-Aug-10 | 1677 |
| 05-Sep-10 | 1708 |
| 12-Sep-10 | 1738 |
| 19-Sep-10 | 1768 |
| 26-Sep-10 | 1808 |
| 03-Oct-10 | 1898 |
| 10-Oct-10 | 1988 |
| 17-Oct-10 | 2080 |
| 24-Oct-10 | 2150 |
| 31-Oct-10 | 2210 |
| 07-Nov-10 | 2270 |
| 14-Nov-10 | 2330 |
| 21-Nov-10 | 2384 |
| 28-Nov-10 | 2454 |
| 05-Dec-10 | 2547 |
| 12-Dec-10 | 2637 |
| 19-Dec-10 | 2727 |
| 26-Dec-10 | 2827 |
| 02-Jan-11 | 2878 |
| 09-Jan-11 | 2928 |
| 16-Jan-11 | 3011 |
| 23-Jan-11 | 3008 |
| 30-Jan-11 | 3008 |
| 06-Feb-11 | 3007 |
| 13-Feb-11 | 2930 |
| 20-Feb-11 | 2820 |
| 27-Feb-11 | 2710 |
| 06-Mar-11 | 2629 |
| 13-Mar-11 | 2549 |
| 20-Mar-11 | 2475 |
| 27-Mar-11 | 2394 |
| 03-Apr-11 | 2314 |
| 10-Apr-11 | 2234 |
| 17-Apr-11 | 2154 |
| 24-Apr-11 | 2074 |
| 01-May-11 | 1974 |
| 08-May-11 | 1933 |
| 15-May-11 | 1893 |
| 22-May-11 | 1853 |
| 29-May-11 | 1813 |
| 05-Jun-11 | 1783 |
| 12-Jun-11 | 1752 |
| 19-Jun-11 | 1722 |
| 26-Jun-11 | 1692 |
| 03-Jul-11 | 1662 |

NB Electricity Market 18-month Load Forecast, by week

| Week Beg. Sundays | Load Forecast(MW) |
|----------------------|----------------------|
| 10-Jul-11 | 1662 |
| 17-Jul-11 | 1662 |
| 24-Jul-11 | 1662 |
| 31-Jul-11 | 1662 |
| 07-Aug-11 | 1652 |
| 14-Aug-11 | 1642 |
| 21-Aug-11 | 1652 |
| 28-Aug-11 | 1672 |
| 04-Sep-11 | 1703 |
| 11-Sep-11 | 1733 |
| 18-Sep-11 | 1763 |
| 25-Sep-11 | 1793 |
| 02-Oct-11 | 1863 |
| 09-Oct-11 | 1932 |
| 16-Oct-11 | 2002 |
| 23-Oct-11 | 2072 |
| 30-Oct-11 | 2132 |
| 06-Nov-11 | 2298 |
| 13-Nov-11 | 2360 |
| 20-Nov-11 | 2420 |
| 27-Nov-11 | 2501 |
| 04-Dec-11 | 2600 |
| 11-Dec-11 | 2700 |
| 18-Dec-11 | 2801 |
| 25-Dec-11 | 2880 |
| 01-Jan-12 | 2917 |
| 08-Jan-12 | 2956 |
| 15-Jan-12 | 2996 |
| 22-Jan-12 | 3036 |
| 29-Jan-12 | 3070 |
| 05-Feb-12 | 3070 |
| 12-Feb-12 | 2950 |
| 19-Feb-12 | 2831 |
| 26-Feb-12 | 2721 |

The following includes the details of the ambient conditions on which the forecast is based.

The load forecast is based on an End-use Model (sum of forecasted loads by use e.g. water heating, space heating, lighting etc.) for residential loads and an Econometric Model for general service and industrial loads, correlating forecasted economic growth and historical loads. Each of these models is weather adjusted using a 30-year historical average.